

NOV 11 1976

NOTE:  
 White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
 Form 3300-15  
 Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Clayton Tap Dist. Name

2. LOCATION SW 15 10 N 4 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Wilbert Holliday  
 ADDRESS RFD  
 POST OFFICE Lays Mills, WI 54631

AND - If available subdivision name, lot & block No.

4. Distance in feet from well to nearest: (Record answer in appropriate block) 20'

Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer  Other Sewers  Foundation Drain Connected to: 160'

San.	Storm	C.I.	Other	Sewer	Clearwater Dr.	Sewage Sump	Clearwater Sump	C.I.	Other	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit
<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<u>160'</u>

Privy  Pet Waste Pit  Pit: Nonconforming Existing  Well  Pump  Tank  Subsurface Pumproom  Nonconforming Existing  Barn Gutter  Animal Barn Pen  Animal Yard  Silo With Pit  Glass Lined Storage Facility  Silo w/o Pit  Earthen Silage Storage Trench Or Pit

Temporary Manure Stack  Watertight Liquid Manure Tank  Solid Manure Storage Structure  Subsurface Gasoline or Oil Tank  Waste Pond or Land Disposal Unit (Specify Type)  Other (Give Description)

5. Well is intended to supply water for: Mobil home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Sand</u>	<u>0</u> Surface	<u>30</u>
<u>Clay &amp; Rock</u>	<u>30</u>	<u>45</u>
<u>Shale stone</u>	<u>45</u>	<u>75</u>
<u>Sand Rock</u>	<u>75</u>	<u>140</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>52</u>	<u>6</u>	<u>52</u>	<u>140</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>P.E. New Black Steel 18.97</u>	<u>0</u> Surface	<u>52</u>
	<u>Valley Steel A-53</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay Cement</u>	<u>0</u> Surface	<u>52</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with  Air  Water

Rotary-air w/drilling mud  Rotary-hammer & air

Rotary-w/drilling mud  Reverse Rotary

Well construction completed on Oct 15 1976

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 80 Ft.

Depth of water level when pumping 87 Ft. Stabilized  Yes  No

Well is terminated 12 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on Nov. 9 1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Capron Registered Well Driller

Complete Mail Address R 3 - Box 84 - Boscobel, WI 53805