

MAR 20 1980

WELL CONSTRUCTOR'S REPORT  
RM 3300-15

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

COUNTY Crawford CHECK ONE  Town  Village  City Clayton

LOCATION - 1/4 Section NE Section 15 Township 10N Range 4W 3. OWNER AT TIME OF DRILLING Verne Isabell

- Grid or street no. Street name ADDRESS R7D

D - If available subdivision name, lot & block no. POST OFFICE Gay Mills, Wis. 54631

Distances in feet from well to nearest: (Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE
<u>18'</u>	<u>26'</u>	<u>26'</u>				

SEWER WATER DRAIN C.I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	<u>54'</u>			<u>80'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

Well is intended to supply water for: Trailer home

DRILLHOLE						9. FORMATIONS		
dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>65</u>	<u>6</u>	<u>65</u>	<u>100</u>	<u>loose sand</u>	<u>Surface</u>	<u>15</u>
						<u>soft sandstone</u>	<u>15</u>	<u>50</u>
						<u>hard shalestone</u>	<u>50</u>	<u>100</u>

CASING, LINER, CURBING, AND SCREEN

dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 18.97</u>	<u>Surface</u>	<u>65</u>

GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>loose sand</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>65</u>

MISCELLANEOUS DATA

Flow test: 3 Hrs. at 5 GPM

Depth from surface to normal water level 58 ft.

Depth to water level when pumping 64 ft.

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

Well construction completed on 9-25-1975

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 10-29-1975

Driller's opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

NATURE OF WELL Domestic COMPLETE MAIL ADDRESS Boscobel

Driller Kenneth Coplan Registered Well Driller R3 Box 84 Wisconsin 53805

Please do not write in space below

WELL TEST RESULT	C.S. - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>906</u>				