

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

OCT 11 1971

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section SW Section 17 Township 10N Range 4W 3. OWNER AT TIME OF DRILLING Micael Welch

OR - Grid or street no. Street name ADDRESS R7D Gays Mills,

AND - If available subdivision name, lot & block no. POST OFFICE Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C.I.	C.I.	C.I.	SEWER CONNECTED	INDEPENDENT
<u>5'</u>	<u>20'</u>	<u>20'</u>		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C.I.	TILE							
	<u>60'</u>			<u>70'</u>				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Trailer home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>54</u>	<u>6</u>	<u>54</u>	<u>100</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>limestone</u>	<u>15</u>	<u>80</u>
<u>sandstone</u>	<u>80</u>	<u>100</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>54</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>15</u>
<u>Cement</u>	<u>15</u>	<u>54</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 9-20-1971

11. MISCELLANEOUS DATA

Yield test: 5 Hrs. at 8 GPM

Well is terminated 10 inches above below final grade

Depth from surface to normal water level 60 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 65 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 10-6-1971

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Benneth Pospian Registered Well Driller COMPLETE MAIL ADDRESS R3 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>909</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71