

MAR 7 1979

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City Name Utica													
2. LOCATION 1/2 Section NE Section 19 Township 10N Range 4W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE Dorothy Cummings ADDRESS Rt 1 POST OFFICE Gays Mills, Wis 54631													
OR - Grid or Street No. Street Name		AND - If available subdivision name, lot & block No.													
4. Distance in feet from well to nearest: (Record answer in appropriate block) 80		Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer			
		C.I. Other		C.I. Other		C.I. Other		C.I. Other		C.I. Other		C.I. Other			
Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank			
San. Storm		C.I. Other		Sewer		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank			
				Clearwater Dr.		Clearwater Sump									
Privy		Pet Waste Pit		Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter		Animal Barn Pen		Animal Yard			
				Well		Nonconforming Existing									
				Pump											
				Tank											
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)					
5. Well is intended to supply water for: New Home						9. FORMATIONS									
6. DRILLHOLE						Kind									
Dia. (in.)		From (ft.)		To (ft.)		Dia. (in.)		From (ft.)		To (ft.)		From (ft.)		To (ft.)	
10		Surface		43		6		43		125		Top soil		Surface	
												Clay		2	
												Gray shale		20	
														125	
7. CASING, LINER, CURBING AND SCREEN															
Material, Weight, Specification & Method of Assembly															
Dia. (in.)		From (ft.)		To (ft.)		Dia. (in.)		From (ft.)		To (ft.)					
6		Surface		43		6		43							
Steel 40 18:97 P.E.															
Pitless Adapter															
ASTM-A-53															
American Steel															
8. GROUT OR OTHER SEALING MATERIAL						10. TYPE OF DRILLING MACHINE USED									
Kind		From (ft.)		To (ft.)											
Backfill W/ Native Soil		Surface		8		<input checked="" type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Rotary-air w/drilling mud <input type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air <input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water									
Cement grout		8		43		Well construction completed on Feb 28, 19 79									
11. MISCELLANEOUS DATA						Well is terminated 12 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below									
Yield Test: 2		Hrs. at 8		GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									
Depth from surface to normal water level 50		Ft.				Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No									
Depth of water level when pumping 55		Ft.		Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No											
Water sample sent to State laboratory on Feb 28, 19 79															
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.															
Signature Albin Herbeck #482 Registered Well Driller						Complete Mail Address Box 136 Richland Center, Wis 53581									

912