

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

MAY 03 1974

48649

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

| | | | | | | | |
|---|--------------------|--|----------------------------|--------------------------------|---|--------------------------------|--|
| 1. COUNTY <u>Crawford</u> | | CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City | | | NAME <u>Utica</u> | | |
| 2. LOCATION - 1/4 Section <u>NE</u> Section <u>19</u> Township <u>10N</u> Range <u>4W</u> | | 3. OWNER AT TIME OF DRILLING <u>agent Russell</u> | | | | ADDRESS <u>RFD. Gap Mills</u> | |
| OR - Grid or street no. | | Street name | | POST OFFICE <u>Wis., 54631</u> | | | |
| 4. Distance in feet from well to nearest: (Record answer in appropriate block) | | BUILDING 20' | SANITARY SEWER C.I. 30' | FLOOR DRAIN C.I. | FOUNDATION DRAIN SEWER CONNECTED INDEPENDENT | WASTE WATER DRAIN C.I. TILE | |
| CLEAR WATER DRAIN C.I. TILE | SEPTIC TANK 50' | PRIVY | SEEPAGE PIT | ABSORPTION FIELD 60' | BARN | SILO | |
| | | | | | ABANDONED WELL | SINK HOLE | |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Township garage

| 6. DRILLHOLE | | | | | | 7. FORMATIONS | | |
|--------------|------------|----------|------------|------------|----------|----------------|------------|----------|
| Dia. (in.) | From (ft.) | To (ft.) | Dia. (in.) | From (ft.) | To (ft.) | Kind | From (ft.) | To (ft.) |
| 10 | Surface | 264 | 6 | 264 | 320 | Clay | Surface | 15 |
| | | | | | | Clay & stone | 15 | 30 |
| | | | | | | Limestone | 30 | 180 |
| | | | | | | soft sandstone | 180 | 250 |
| | | | | | | Limestone | 250 | 320 |

| | | | |
|------------------------------------|------------|---|---|
| 8. GROUT OR OTHER SEALING MATERIAL | | 10. TYPE OF DRILLING MACHINE USED | |
| Kind | From (ft.) | To (ft.) | <input type="checkbox"/> Cable Tool <input type="checkbox"/> Direct Rotary <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Rotary - air w/drilling mud <input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water |
| <u>Clay</u> | Surface | 15 | |
| <u>Cement</u> | 15 | 264 | |
| | | Well construction completed on <u>4-18</u> 19 <u>74</u> | |

| | | | |
|--|-------------------------------|--|--|
| 11. MISCELLANEOUS DATA | | Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade | |
| Yield test: | <u>3</u> Hrs. at <u>8</u> GPM | | |
| Depth from surface to normal water level | <u>250</u> ft. | Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |
| Depth to water level when pumping | <u>254</u> ft. | Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No | |

Water sample sent to Madison laboratory on: 4-30- 1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

| | |
|--|--|
| SIGNATURE <u>Kenneth Coplan</u> Registered Well Driller | COMPLETE MAIL ADDRESS <u>R3 Box 84</u> <u>Boscobel,</u> <u>Wis., 53805</u> |
|--|--|

| | | | | |
|----------------------|---------------|---------------|-----------|---------|
| COLIFORM TEST RESULT | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
| REV. 3-71 <u>913</u> | | | | |