

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15

OCT 15 1979

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Utica	
2. LOCATION OR - Grid or Street No. SE Section 21 Township 10N Range 4W		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE John R. Johnson		ADDRESS R3D	
AND - If available subdivision name, lot & block No.		POST OFFICE Gays Mills, Wis., 54631			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 30'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer		Other Sewers		Foundation Drain Connected to:	
San. Storm C.I. Other		Sewer		Sewage Sump C.I. Other	
		Clearwater Dr.		Clearwater Sump	
				Sewage Absorption Unit 65'	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy		Pet Waste Pit		Pit: Nonconforming Existing	
				Subsurface Pumproom Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
				Other (Give Description)	
5. Well is intended to supply water for: Country homes				9. FORMATIONS	
6. DRILLHOLE				Kind	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)				From (ft.) To (ft.)	
10 Surface 0 57 6 57 120				Clay & stone Surface 0 15	
				soft shale stone 15 40	
				hard shale stone 40 90	
				sandstone 90 120	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly					
Dia. (in.)		From (ft.)		To (ft.)	
6		new black steel P.E. 18.97		0 57	
		A-53			
		Keystone Pipe			
		Pitless adapter			
8. GROUT OR OTHER SEALING MATERIAL					
Kind		From (ft.)		To (ft.)	
Clay		Surface		8	
Cement		8		57	
10. TYPE OF DRILLING MACHINE USED					
<input type="checkbox"/> Cable Tool		<input type="checkbox"/> Rotary-hammer w/drilling mud & air		<input type="checkbox"/> Jetting with	
<input type="checkbox"/> Rotary-air w/drilling mud		<input checked="" type="checkbox"/> Rotary-hammer & air		<input type="checkbox"/> Air	
<input type="checkbox"/> Rotary-w/drilling mud		<input type="checkbox"/> Reverse Rotary		<input type="checkbox"/> Water	
Well construction completed on 9-18-1979					
11. MISCELLANEOUS DATA					
Yield Test: 3 Hrs. at 5 GPM		Well is terminated 10 inches		<input checked="" type="checkbox"/> above final grade	
				<input type="checkbox"/> below	
Depth from surface to normal water level 70 Ft.		Well disinfected upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth of water level when pumping 82 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		Well sealed watertight upon completion		<input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to Madison				laboratory on 10-9-1979	
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature Kenneth Coplan Registered Well Driller			Complete Mail Address R2 Box 4 Boscobel, Wis. 53805		