

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

APR 7 1981

1. COUNTY Crawford		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name Scott	
2. LOCATION OR - Grid or Street No. SW 34 <input checked="" type="checkbox"/> 9N 3W		3. NAME <input checked="" type="checkbox"/> OWNER Gary Meyer <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE		ADDRESS RR2	
AND - If available subdivision name, lot & block No.		POST OFFICE Boscobel, WI			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building 25'		Sanitary Bldg. Drain C.I. Other	
		Sanitary Bldg. Sewer C.I. Other 50'		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm C.I. Other		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump	
		Sewage Sump C.I. Other		Clearwater Sump	
Septic Tank 70'		Holding Tank		Sewage Absorption Unit 100' Seepage Pit Seepage Bed Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumphoom Nonconforming Existing	
		Barn Gutter		Animal Barn Pen 100'	
		Animal Yard		Silo With Pit	
		Glass Lined Storage Facility		Silo w/o Pit 65'	
		Earthen Silage Storage Trench Or Pit			
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: farm			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
10 Surface 0 230 6 230 340			clay Surface 0 17		
			broken limestone 17 215		
			limestone (hard) 215 238		
			hard sandstone 238 296		
			hard shale 296 340		
7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly			10. TYPE OF DRILLING MACHINE USED		
Dia. (in.) From (ft.) To (ft.)			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
6 A-53; P.E. 0 Surface 230			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
18.97/ft			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
new black steel			Well construction completed on 3-25 19 81		
pitless adapter			Well is terminated 12 inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
8. GROUT OR OTHER SEALING MATERIAL			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Kind From (ft.) To (ft.)			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
clay 0 8			Water sample sent to Madison laboratory on 3-30 19 81		
cement 8 230			Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.		
11. MISCELLANEOUS DATA			Signature Paul Coplan Registered Well Driller		
Yield Test: 2 Hrs. at 10 GPM			Complete Mail Address 308 E. Bluff		
Depth from surface to normal water level 280 Ft.			Boscobel, WI 53805		
Depth of water level when pumping 290 Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					