

JAN 30 1976

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Clayton

2. LOCATION - 1/4 Section NW Section 21 Township 10N Range 4W 3. OWNER AT TIME OF DRILLING Larry Olson
OR - Grid or street no. Street name ADDRESS R7D

AND - If available subdivision name, lot & block no. POST OFFICE Gays Mills, Wis. 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE		
12'	25'	25'						
CLEAR WATER DRAIN C. I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILLO	ABANDONED WELL	SINK HOLE
	60'			80'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	From (ft.)	To (ft.)
10	Surface	92	6	92	120	loose sand	Surface	75
						hard sandstone	75	120

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.97 A-53 Valley Steel	Surface	92

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
loose sand	Surface	75
Cement	75	92

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer Jetting with Air Water

Well construction completed on 1-10-1976

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 5 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 70 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 76 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 1-26-1976

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel Wis. 53805

COLIFORM TEST RESULT 920 GAS - 24 HRS. GAS - 48 HRS. CONFIRMED REMARKS

REV. 3-71