

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

JUL 30 1975

NOTE  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Hayes Mills

2. LOCATION - 1/4 Section SW-NE Section 21 Township 10N Range 4W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Jerrance Skelley  
ADDRESS Hayes Mills

AND If available subdivision name, lot & block no. lot 3 & 4 POST OFFICE Wis., 54631

4. Distance in feet from well to nearest:  
(Record answer in appropriate block)

BUILDING C.I.	SANITARY C.I.	SEWER TILE	FLOOR DRAIN C.I.	FLOOR DRAIN TILE	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN TILE
	30'	45'					45'

CLEAR WATER DRAIN C.I.	CLEAR WATER DRAIN TILE	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
		80'			90'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	62'	6	62	140	Clay	Surface	15
						shale & sandstone	15	40
						hard shalestone	40	100
						sandstone	100	140

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	new black steel plain end 18.97	Surface	62

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	15
Cement	15	62

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary  
 Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with  Air  Water

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well construction completed on July 14 - 1975

Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 70 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 76 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 7-28-1975

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Cospian Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Boscobel, Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>921</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				