

JUN 24 1977

NOTE:  
White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City		Name <u>Clayton</u>	
2. LOCATION OR - Grid or Street No. <u>NE</u> <u>22</u> <u>10N</u> <u>4W</u>		3. NAME <input checked="" type="checkbox"/> OWNER <input type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Pat Brockway</u>		ADDRESS <u>RFD</u>	
AND - If available subdivision name, lot & block No.		POST OFFICE <u>Lays Mills, WI</u>			
4. Distance in feet from well to nearest: (Record answer in appropriate block)		Building <u>25'</u>		Sanitary Bldg. Drain C.I. Other <u>25'</u>	
		Sanitary Bldg. Sewer C.I. Other		Floor Drain Connected To: C.I. Sewer Other Sewer	
		Storm Bldg. Drain C.I. Other		Storm Bldg. Sewer C.I. Other	
Street Sewer San. Storm		Other Sewers C.I. Other		Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr.	
				Sewage Sump C.I. Other	
				Clearwater Sump	
				Septic Tank <u>75</u>	
				Holding Tank	
				Sewage Absorption Unit <u>80</u>	
				Seepage Pit	
				Seepage Bed	
				Seepage Trench	
Privy Pet Waste Pit		Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumproom Nonconforming Existing	
				Barn Gutter	
				Animal Barn Pen	
				Animal Yard	
				Silo With Pit	
				Glass Lined Storage Facility	
				Silo w/o Pit	
				Earthen Silage Storage Trench Or Pit	
Temporary Manure Stack		Watertight Liquid Manure Tank		Solid Manure Storage Structure	
				Subsurface Gasoline or Oil Tank	
				Waste Pond or Land Disposal Unit (Specify Type)	
		Other (Give Description)			
5. Well is intended to supply water for: <u>Trailer Home</u>			9. FORMATIONS		
6. DRILLHOLE			Kind		
Dia. (in.) From (ft.) To (ft.)			From (ft.) To (ft.)		
<u>10</u> <u>Surface</u> <u>42</u> <u>6</u> <u>42</u> <u>85</u>			<u>Clay</u> <u>Surface</u> <u>0</u> <u>15</u>		
			<u>Hard Shalestone</u> <u>15</u> <u>35</u>		
			<u>Sandstone</u> <u>35</u> <u>85</u>		
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly			From (ft.) To (ft.)		
<u>6</u> <u>P.E. New Blacksteel</u> <u>A-53 18.97</u>			<u>Surface</u> <u>0</u> <u>42</u>		
<u>Valley Steel</u>					
<u>Pitless Adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind			From (ft.) To (ft.)		
<u>Clay</u> <u>Surface</u> <u>0</u> <u>7</u>			<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with		
<u>Cement</u> <u>7</u> <u>42</u>			<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Air		
			<input type="checkbox"/> Rotary-w/drilling mud <input type="checkbox"/> Reverse Rotary <input type="checkbox"/> Water		
11. MISCELLANEOUS DATA			Well construction completed on <u>June 3</u> 19 <u>77</u>		
Yield Test: <u>3</u> Hrs. at <u>5</u> GPM			Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below		
Depth from surface to normal water level <u>45</u> Ft.			Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Depth of water level when pumping <u>48</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		
Water sample sent to <u>Madison</u> laboratory on <u>June 20</u> 19 <u>77</u>					
Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.					
Signature <u>Kenneth Copian</u> Registered Well Driller <u>924</u>			Complete Mail Address <u>R3, Box 84 - Roschele, WI 53805</u>		