U61L16

JUN 7 1946
4/15

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH

See Instructions on Reverse Side

1. County Crawford {Town Village City} Clayton
2. Location NW, NW, sec, 26, Range 4W, T, 10,N, N. W. of N.W.
3. Owner or Agent Wis Orchards Inc.
4. Address Gays Mill Wis
5. From well to nearest: Building 50' ft; sewer ___ ft; drain ___ ft; septic tank ___ ft; dry well or filter bed ___ ft; abandoned well ___ ft.
6. Well is intended to supply water for: spraying Purpose,

7. DRILLHOLE OR EXCAVATION:

Dia. (in.)	From (ft.)	To (ft.)
6.	0	410'

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
6.	Standard	0	43½'

9. GROUT:

Kind	From (ft.)	To (ft.)

10. FORMATIONS:

Kind	Thickness (ft.)	Total Depth (ft.)
top Soil lose Rock.	40	.40
lime Rock.	185.	225
sand Rock.	100.	325
Blue shale.	85	410'

11. MISCELLANEOUS DATA:

Yield test: 4 Hrs. at 4½ GPM.

Depth from surface to water: 290' ft.

Water-level when pumping: 290' ft.

Water sample sent to laboratory at

___ on ___ 19___

Signature E S Waters
Registered Well Driller

Construction of the well was completed on May 9. 1946

The well is terminated 12 inches (above) (below) the permanent grade.

Was the well disinfected upon completion? Yes ✓ No ___

Was the well sealed watertight upon completion? Yes ✓ No ___

500 Walnut St. Boscobel Wis
Complete Mail Address

CR
929