

NOTE:
 White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

FEB 7 0 1986

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Haney

2. LOCATION NW 1/4 NW 1/4 Section 2 Township 9N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS Douglas Meyers
326 S.E. Ave
 POST OFFICE Viroqua ZIP CODE WI 54665

4. Distance in feet from well to nearest: (Record answer in appropriate block) 10'

Building	Sanitary Bldg. Drain	Sanitary Bldg. Sewer	Floor Drain Connected To:	Storm Bldg. Drain	Storm Bldg. Sewer
	C.I. Other	C.I. Other	C.I. Sewer Other Sewer	C.I. Other	C.I. Other

Street Sewer	Other Sewers	Foundation Drain Connected to:	Sewage Sump	Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit	Manure Hopper or Retention or Pneumatic Tank
San. Storm	C.I. Other	Sewer	Sewage Sump	Clearwater Sump			Seepage Pit	
		Clearwater Dr.	Clearwater Sump				Seepage Bed <u>175'</u>	Seepage Trench

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Storage Trench Or Pit	Earthen Manure Basin
		Well	Nonconforming Existing								
		Pump									
		Tank									

Temporary Manure Stack or Platform	Watertight Liquid Manure Tank or Basin	Manure Pressure Pipe	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Manure Storage Basin	Other (Describe)
					Concrete Floor Only	
					Concrete Floor and Partial Concrete Walls	

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10"</u>	<u>0</u>	<u>84</u>			
<u>6"</u>	<u>84</u>	<u>120</u>			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
<u>6"</u>	<u>Plain End New Black Steel</u>	<u>0</u>	<u>84</u>
	<u>ASTM A-120</u>		
	<u>.280W</u>		
	<u>KSP Steel</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Pitless Adaptor</u>	<u>0</u>	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>84</u>

9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Loose sand</u>	<u>0</u>	<u>19</u>
<u>Sand rock</u>	<u>19</u>	<u>39</u>
<u>Soft shale</u>	<u>39</u>	<u>82</u>
<u>Shale</u>	<u>82</u>	<u>97</u>
<u>Sandrock</u>	<u>97</u>	<u>120</u>

10. TYPE OF DRILLING MACHINE USED

<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Rotary-hammer w/drilling mud & air	<input type="checkbox"/> Jetting with
<input type="checkbox"/> Rotary-air w/drilling mud	<input checked="" type="checkbox"/> Rotary-hammer & air	<input type="checkbox"/> Air
<input type="checkbox"/> Rotary-w/drilling mud	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Water

Well construction completed on 12-30 19 85

11. MISCELLANEOUS DATA

Yield Test: 2 Hrs. at 7 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 43 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 65 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON WI. laboratory on 2-4 19 86

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Bainborn Registered Well Driller
 Business Name and Complete Mailing Address CORPIAN WELL DRILLING INC.
R.R. 2 Box 4 Boscobel, WI 53805

94