

AUG 19 1977

State of Wisconsin  
Department of Natural Resources  
Box 7921  
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy  
Green Copy - Driller's Copy  
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT  
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Utica

2. LOCATION ¼ Section NW Section 1 Township 10 N Range 5 W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Gerald Halverson  
OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 50' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 70'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer home

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Clay	0 Surface	18
limestone	18	90
sandstone	90	125

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10	Surface	106	6	106	290

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	new black steel P.E. 18.99 A-53	Surface	106

Valley Steel  
Pitless adaptor

Kind	From (ft.)	To (ft.)
limestone	125	260
sandstone	260	290

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	7
Cement	7	106

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-hammer w/drilling mud & air  Jetting with

Rotary-air w/drilling mud  Rotary-hammer & air  Air

Rotary-w/drilling mud  Reverse Rotary  Water

Well construction completed on 7-27-1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 6 GPM

Depth from surface to normal water level 220 Ft.

Depth of water level when pumping 226 Ft. Stabilized  Yes  No

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 8-15-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Copian Registered Well Driller Complete Mail Address Boacabel, Wis., R3 Box 84 53805

941