

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Udica

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)

Rt 9 SE 1/4 56 1/4 Sec 3 - TSP 10 - RP-5W on 1427

3. OWNER AT TIME OF DRILLING Paul Lach

4. OWNER'S COMPLETE MAIL ADDRESS Therrellville Wis

5. Distance in feet from well to nearest: (Record answer in appropriate block)	BUILDING	SANITARY	SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Home

7. DRILLHOLE						10. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind		From (ft.)	To (ft.)
10"	Surface	60	6"	60	335	Clay		Surface	20
						Sandstone		20	100

8. CASING, LINER, CURBING, AND SCREEN				
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Remarks
6"	19.18 - New Steel Blk	Surface	60	Lined Sandstone
				Sandstone

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
<u>Cement</u>	Surface	60

Well construction completed on 10/21 1969

11. MISCELLANEOUS DATA  
Yield test: 26 Hrs. at 10 GPM Well is terminated 12 inches  above  below final grade

Depth from surface to normal water level 285 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 320 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 11/3 1969

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphrooms, access pits, etc., should be given on reverse side.

SIGNATURE [Signature] Registered Well Driller COMPLETE MAIL ADDRESS Therrellville Iowa IA 55

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
----------------------	---------------	---------------	-----------	---------