

1. COUNTY **CRAWFORD** CHECK ONE **FREEMAN TOWNSHIP**
 Town Village City

2. LOCATION (Number and Street or ¼ section, section, township and range. Also give subdivision name, lot and block numbers when available.)
NORTH ½ OF N.W. ¼ OF SEC. 5-- TWN. 10 --- RANGE 5 W.

3. OWNER AT TIME OF DRILLING
SUGAR CREEK VALLEY BIBLE CAMP, LaCROSS, VIROQUE, DODGEVILLE CONFERENCE INC.

4. OWNER'S COMPLETE MAIL ADDRESS
FERRYVILLE, WIS. 54628
(OF AMERICAN LUTHERAN CHURCH

5. Distance in feet from well to nearest: (Record answer in appropriate block)

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	C. I.
TILE	INDEPENDENT	TILE		TILE
30'				

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SLO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	NONE	NONE	NONE	NONE	30'		NONE	NONE

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

CREEK ABOUT 1000 FT. FROM WELL

6. Well is intended to supply water for:

DRINKING WATER FOR CAMPERS.

7. DRILLHOLE						10. FORMATIONS			
Dis. (in.)	From (ft.)	To (ft.)	Dis. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
6"	Surface	214					Surface		
10"	"	30'				SANDY DRIFT.	0'	20'	
8. CASING, LINER, CURBING, AND SCREEN									
Dis. (in.)	Kind and Weight		From (ft.)	To (ft.)					
10"	STANDARD PIPE		Surface	30'		GREEN SHALE	20'	148'	
6"	STANDARD PIPE 19.45 #per foot		"	148'		WHITE SAND	148'	214'	
PLAIN END CASING									
6"	CASING HAS DRIVE SHO ON AND IS DROVE INTO THE SAND.								
9. GROUT OR OTHER SEALING MATERIAL									
Kind			From (ft.)	To (ft.)					
NEAT CEMENT			Surface	148'					

Well construction completed on **JUNE 10** 19 **69**

11. MISCELLANEOUS DATA

Yield test: **4** Hrs. at **20** GPM

Well is terminated **inches** above below final grade

Depth from surface to normal water level **80'** ft. Well disinfected upon completion Yes No

Depth to water level when pumping **100** ft. Well sealed watertight upon completion Yes No

Water sample sent to **MADISON- FIRST SAMPLE ON 6-16-69** laboratory on **second SAMPLE ON JULY 1** 19 **69**

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphoms, access pits, etc., should be given on reverse side.

SIGNATURE **LEWIS HARRIS** **327 N. MAIN ST. PRAIRIE DU CHIEN, WIS. 53821**
Lewis Harris Registered Well Driller

Please do not write in space below

COLIFORM TEST RESULT	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
949				CC Region 1

WGNHS ORIGINAL