

NOV 18 1985
 SEP 24 1985

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Haney

2. LOCATION N, NE 1/4 Section 3 Township 9N Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Donald C. Yonker

OR - Grid or Street No. Street or Road Name ADDRESS Rt. 2 Box 200

AND - If available subdivision name, lot & block No. POST OFFICE Gays Mills WI ZIP CODE 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 10' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed 200' Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Storage Trench Earthen Silage Trench Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Private

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
10"	0 Surface	79			
6"	79	100			

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6"	Plain End New Black Steel .280W x #18.97 CA Condaven A-53	0 Surface	79

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Pitless Adaptor	0 Surface	7
Cement	7	79

9. FORMATIONS

Kind	From (ft.)	To (ft.)
Loose Sand	0 Surface	73
Gravel	73	78
Sand Rock	78	100

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 9-12 19 85

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 8 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 44 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 56 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to MADISON WI laboratory on 9/17 19 85

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Michael D. Bamber Registered Well Driller

Business Name and Complete Mailing Address
CORPIAN WELL DRILLING INC.
R.R. 2 Boscobel, WI. 53805