

NOV 30 1972

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE
WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION - 1/4 Section SW Section 7 Township 10N Range 5W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Stevenson Bros
ADDRESS R7D2
POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest:
(Record answer in appropriate block)

BUILDING C.I.	SANITARY SEWER TILE	FLOOR DRAIN C.I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C.I.	WASTE WATER DRAIN TILE		
<u>8'</u>	<u>40'</u>	<u>40'</u>						
CLEAR WATER DRAIN C.I.	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	<u>70'</u>			<u>90'</u>	<u>200'</u>	<u>200'</u>		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u>	<u>127</u>	<u>6</u>	<u>127</u>	<u>500</u>	<u>Clay</u>	<u>Surface</u>	<u>25</u>	
						<u>limestone</u>	<u>25</u>	<u>215</u>	
						<u>hard shalestone</u>	<u>215</u>	<u>300</u>	
						<u>limestone</u>	<u>300</u>	<u>450</u>	
						<u>sandstone</u>	<u>450</u>	<u>500</u>	

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)					
<u>Clay</u>	<u>Surface</u>	<u>25</u>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with	<input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>25</u>	<u>127</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air			
				Well construction completed on <u>11-23-1972</u>			

11. MISCELLANEOUS DATA				Well is terminated			
Yield test:	<u>3</u> Hrs. at	<u>6</u> GPM		<u>12</u> inches	<input checked="" type="checkbox"/> above	<input type="checkbox"/> below	final grade
Depth from surface to normal water level	<u>390</u> ft.				<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	
Depth to water level when pumping	<u>410</u> ft.				<input checked="" type="checkbox"/> Yes	<input type="checkbox"/> No	

Water sample sent to Madison laboratory on: 11-27-1972

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel
R3 Box 84 Wis. 53805

COLIFORM TEST RESULT <u>951</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------