

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

Crawford AUG 16 1974

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION -- 1/4 Section pt SW 1/4 Sec 7 Section 10 Township 5 W Range 5 W

OR - Grid or street no. pt SW 1/4 Sec 7 Street name 10

3. OWNER AT TIME OF DRILLING Lorel Wagner
ADDRESS Ferryville Wise R-
POST OFFICE

AND - If available subdivision name, lot & block no.

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
15'	C. I. TILE	C. I. TILE	SEWER CONNECTED INDEPENDENT	C. I. TILE

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I. TILE	55'			70'				

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for:

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10"	Surface	106'	6"	106	474	0 - 20	Surface	drift	
						20 - 100		Limestone	
						Sandstone	100	300	
						Blue Rock	300	430	
						Sandstone	430	474	

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6"	T/C BLK 1945# New	Surface	106

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Cement	Surface	106

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary

Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 8/1 19 74

11. MISCELLANEOUS DATA

Yield test: 10 Hrs. at 15 GPM

Well is terminated 12 inches above below final grade

Depth from surface to normal water level 414 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 434 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 8/15 19 74

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Edwin W. Meyer Registered Well Driller COMPLETE MAIL ADDRESS New Albany Iowa

Please do not write in space below

COLIFORM TEST RESULT <u>953</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------

REV. 3-71