

SEP 20 1976

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
 Form 3300-15
 Rev. 10-75

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Seneca

2. LOCATION SW 10 Township 10N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS Roy Schwartz
RFD
 POST OFFICE Ferrisville, WI

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. 30' Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewage Sump Clearwater Sump Clearwater Dr. Sewage Sump Clearwater Sump Clearwater Dr. Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 80'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Trailer Home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	0 Surface	110	6	110	160	Clay	0	20
						Soft Shalestone	20	100
						Hard Sandstone	100	160

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
6	PE, New Blacksteel 18.97 Valley Steel A-53 Pitless Adapters	0 Surface	110

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	0 Surface	8
Cement	8	110

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on Aug 31 19 76

Well is terminated 10 inches above below final grade

Well disinfected upon completion Yes No

Well sealed watertight upon completion Yes No

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM

Depth from surface to normal water level 120 Ft.

Depth of water level when pumping 120 Ft. Stabilized Yes No

Water sample sent to Madison laboratory on Sept. 13 19 76

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Benneth Coprian Registered Well Driller

Complete Mail Address R3, Box 84 - Boscobel, WI 53805