

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

APR 25 1977

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica

2. LOCATION 1/4 Section SE Section 12 Township 10N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
Raymond Hanson
 OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Soldiers Grove, Wis. 54655

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Sewage Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country Cabin 9. FORMATIONS

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>15</u>
<u>limestone</u>	<u>15</u>	<u>60</u>
<u>sandstone</u>	<u>60</u>	<u>80</u>

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)
<u>10</u>	<u>0</u> Surface	<u>42</u>	<u>6</u>	<u>42</u>	<u>80</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97 A-53</u>	<u>0</u> Surface	<u>42</u>
	<u>Valley Steel</u>		
	<u>Pitless adaptor</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>0</u> Surface	<u>7</u>
<u>Cement</u>	<u>7</u>	<u>42</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 4-18- 1977

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 40 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 48 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 4-20- 1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Popian Registered Well Driller Complete Mail Address R3 Box 84 Boscobel, Wis. 53805