

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

MAY 10 1974

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

1. COUNTY Crawford CHECK ONE Town Village City NAME Utica

2. LOCATION - 1/4 Section S.W. Section 13 Township 10N Range 5W

OR - Grid or street no. Street name ADDRESS R7A

AND - If available subdivision name, lot & block no. POST OFFICE Mt Sterling, Wis. 54645

3. OWNER AT TIME OF DRILLING Vilas Payne

4. Distance in feet from well to nearest:

BUILDING	SANITARY SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE/WATER DRAIN
C. I.	TILE	C. I.	SEWER CONNECTED	INDEPENDENT
<u>75'</u>				

(Record answer in appropriate block)

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	<u>75'</u>			<u>80'</u>	<u>125'</u>	<u>125'</u>	<u>100'</u>	

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	9. FORMATIONS	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>242</u>	<u>6</u>	<u>242</u>	<u>320</u>	<u>Clay</u>		<u>Surface</u>	<u>45</u>
						<u>limestone</u>		<u>45</u>	<u>190</u>
						<u>soft sandstone</u>		<u>190</u>	<u>230</u>
						<u>limestone</u>		<u>230</u>	<u>320</u>

7. CASING, LINER, CURBING, AND SCREEN

Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u>	<u>242</u>

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>45</u>
<u>Cement</u>	<u>45</u>	<u>242</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Direct Rotary Reverse Rotary
 Rotary - air w/drilling mud Rotary - hammer with drilling mud & air Jetting with Air Water

Well construction completed on 4-26-1974

11. MISCELLANEOUS DATA

Yield test: 3 Hrs. at 8 GPM

Well is terminated 8 inches above below final grade

Depth from surface to normal water level 240 ft. Well disinfected upon completion Yes No

Depth to water level when pumping 248 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 5-7-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Henneth Copian Registered Well Driller COMPLETE MAIL ADDRESS Boscobel, R3 Box 84 Wis., 53805

Please do not write in space below

COLIFORM TEST RESULT <u>959</u>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
REV. 3-71				