

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

APR 25 1977

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica

2. LOCATION SE Section 13 Township 10 N Range 5 W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE
 ADDRESS James D. Skvorla
RFD
 POST OFFICE Gay Mills, Wis., 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) 10'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer		
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other	
Street Sewer	Other Sewers	Foundation Drain Connected to:		Sewage Sump		Clearwater Sump	Septic Tank	Holding Tank	Sewage Absorption Unit <u>125'</u>			
San.	Storm	C.I.	Other	Sewer		Clearwater Sump				Seepage Pit		
				Clearwater Dr.		Clearwater Sump				Seepage Bed		
										Seepage Trench		
Privy	Pet Waste Pit	Pit: Nonconforming Existing		Subsurface Pumproom		Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well		Nonconforming Existing								
		Pump										
		Tank										
Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank		Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description)				

5. Well is intended to supply water for: Farm home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<u>10</u>	<u>Surface</u>	<u>217</u>	<u>6</u>	<u>217</u>	<u>290</u>	<u>Clay</u>	<u>Surface</u>	<u>15</u>
						<u>limestone</u>		<u>125</u>
						<u>soft sandstone</u>		<u>205</u>
						<u>limestone</u>		<u>270</u>
						<u>sandstone</u>		<u>290</u>

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel P.E. 18.97</u>	<u>Surface</u>	<u>217</u>
	<u>A-53</u>		
	<u>Valley Steel</u>		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
<u>Clay</u>	<u>Surface</u>	<u>3</u>
<u>Cement</u>	<u>3</u>	<u>217</u>

9. FORMATIONS

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-air w/drilling mud Rotary-w/drilling mud Rotary-hammer w/drilling mud & air Reverse Rotary Jetting with Air Water

Well construction completed on 4-18-1977

11. MISCELLANEOUS DATA

Yield Test: 4 Hrs. at 5 GPM Well is terminated 15 inches above final grade below

Depth from surface to normal water level 200 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 209 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 4-20-1977

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature 960 Kenneth Coprian Registered Well Driller Complete Mail Address Boocobee, Wis. R3 Box 84 53805