

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**  
See Instructions on Reverse Side

RECEIVED  
NOV 13 1950  
SAYBURY

SECTION, SW

1. County Crawford { Town Scott  
Village  
City
2. Location No not have description of property
3. Owner or Agent Otto Rounds
4. Address Boscobel, Wis R.F.D #2
5. From well to nearest: Building 15 ft; sewer \_\_\_\_\_ ft; drain  ft; septic tank  ft;  
dry well or filter bed  ft; abandoned well \_\_\_\_\_ ft.
6. Well is intended to supply water for: Farm use

**7. DRILLHOLE OR EXCAVATION:**

Dia. (in.)	From (ft.)	To (ft.)
5"	0	71

**10. FORMATIONS:**

Kind	Thick-ness (ft.)	Total Depth (ft.)
Black dirt	0	8
Gravel & Sand	8	62
Hard Stone	62	71

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind	From (ft.)	To (ft.)
5"	Black Standard Pipe		
	33 ft used		

**9. GROUT:**

Kind	From (ft.)	To (ft.)

**11. MISCELLANEOUS DATA:**

Yield test: 8 Hrs. at 5 GPM.

Depth from surface to water: 31 ft.

Water-level when pumping: Est Same ft.

Water sample sent to laboratory at June 20 on 1950 19

Construction of the well was completed on June 13 1950

The well is terminated 12 inches (above) (below) the permanent grade.

Was the well disinfected upon completion?  
Yes Yes No \_\_\_\_\_

Was the well sealed watertight upon completion?  
Yes Yes No \_\_\_\_\_

Signature H.W. Bartels  
Registered Well Driller  
Boscobel

202 W. Le Grand St  
Complete Mail Address  
Wisconsin