

NOTE:

White Copy - Division's Copy
 Green Copy - Driller's Copy
 Yellow Copy - Owner's Copy

SEP 19 1978

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Utica

2. LOCATION NW Section 25 Township 10N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Ronald Becwar

OR - Grid or Street No. Street Name ADDRESS R1

AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, Wis, 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) 50'

Building		Sanitary Bldg. Drain		Sanitary Bldg. Sewer		Floor Drain Connected To:		Storm Bldg. Drain		Storm Bldg. Sewer	
		C.I.	Other	C.I.	Other	C.I. Sewer	Other Sewer	C.I.	Other	C.I.	Other

Street Sewer		Other Sewers		Foundation Drain Connected to:		Sewage Sump		Clearwater Sump		Septic Tank		Holding Tank		Sewage Absorption Unit	
San.	Storm	C.I.	Other	Sewer		C.I.	Other							Seepage Pit	
				Clearwater Dr.										Seepage Bed	
														Seepage Trench	

Privy	Pet Waste Pit	Pit: Nonconforming Existing	Subsurface Pumproom	Barn Gutter	Animal Barn Pen	Animal Yard	Silo With Pit	Glass Lined Storage Facility	Silo w/o Pit	Earthen Silage Storage Trench Or Pit
		Well	Nonconforming Existing							
		Pump								
		Tank								

Temporary Manure Stack	Watertight Liquid Manure Tank	Solid Manure Storage Structure	Subsurface Gasoline or Oil Tank	Waste Pond or Land Disposal Unit (Specify Type)	Other (Give Description)
------------------------	-------------------------------	--------------------------------	---------------------------------	---	--------------------------

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
10	Surface	0	6	290	345	Clay & top soil	Surface	0	8
						Clay & broken stone		8	30
						Limestone		30	200

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification & Method of Assembly	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	new black steel R.F. 18.97	Surface	0	soft sandstone	200	250
	A-53			hard sandstone	250	345
	Kent Steel					
	Ritless adaptor					

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
Clay	Surface	0
Cement	8	290

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with

Rotary-air w/drilling mud Rotary-hammer & air Air

Rotary-w/drilling mud Reverse Rotary Water

Well construction completed on 8-30-1978

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches above final grade below

Depth from surface to normal water level 280 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 296 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 9-11-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address Boscobel, Wis, R3 Box 84 53805

973