

WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH  
See Instructions on Reverse Side

RECEIVED

OCT 13 1948

BUREAU  
SAN. ENG.

1. County Grant CRAWFORD { Town  Village  City  Mt Sterling Check one and give name
2. Location Sec 26, 10N, 5W Crawford County  
Name of street and number of premise or Sec./Tn. and R. numbers
3. Owner  or Agent  Mt Sterling State Graded School  
Name of individual, partnership or firm
4. Mail Address Gays Mills, Wisconsin  
Complete address required
5. From well to nearest: Building 15 ft; sewer \_\_\_\_\_ ft; drain \_\_\_\_\_ ft; septic tank \_\_\_\_\_ ft;  
dry well or filter bed \_\_\_\_\_ ft; abandoned well \_\_\_\_\_ ft. toilets 120-125
6. Well is intended to supply water for: School Use

7. DRILLHOLE:

Dia. (in.)	From (ft.)	To (ft.)
8	0	36
6	36	350

10. FORMATIONS:

Kind	From (ft.)	To (ft.)
Sand	0	36
lime rock	36	250
Sand	250	350

8. CASING AND LINER PIPE OR CURBING:

Dia. (in.)	Kind	From (ft.)	To (ft.)
6	Steel	0	36

9. GROUT:

Kind	From (ft.)	To (ft.)
Neat Cement	0	36

11. MISCELLANEOUS DATA:

Yield test: 10 MIN Hrs. at 275 GPM

Depth from surface to water: 200 ft.

Water-level when pumping: 200 ft.

Water sample sent to laboratory at  
Madison on Oct 5 1948

Construction of the well was completed on Sept 15 1948

The well is terminated In pit inches  
 above, below  the permanent ground surface.

Was the well disinfected upon completion?  
Yes \_\_\_\_\_ No ✓

Was the well sealed watertight upon completion?  
Yes ✓ No \_\_\_\_\_

Signature Charles Faberty  
Registered Well Driller  
Platteville

R 7. 11. # 3  
Complete Mail Address  
Wisconsin