

JUL 29 1982

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Nancy

2. LOCATION NW, NE, SW, SE 1/4 Section or Gov't. Lot Section 8 Township Haley Range 4W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Paul E Fairchild

OR - Grid or Street No. Street or Road Name ADDRESS Rt 1

AND - If available subdivision name, lot & block No. POST OFFICE Gays Mills ZIP CODE 54631

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 30' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected To: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Sewage Sump Clearwater Dr. Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit: Seepage Pit Seepage Bed Seepage Trench Manure Hopper or Retention or Pneumatic Tank

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit Earthen Manure Basin

Temporary Manure Stack or Platform Watertight Liquid Manure Tank or Basin Manure Pressure Pipe Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Manure Storage Basin Concrete Floor Only Concrete Floor and Partial Concrete Walls Other (Describe)

5. Well is intended to supply water for: Country home

6. DRILLHOLE

Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	90	6	90	460	clay & rock	Surface	15
						lime rock	15	160
						sand rock	160	280
						shale rock	280	440
						sand rock	440	460

7. CASING, LINER, CURBING AND SCREEN

Dia. (in.)	Material, Weight, Specification	From (ft.)	To (ft.)
6	new black steel PE. 18.97	Surface	90
	A-53		
	Valley steel		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL

Kind	From (ft.)	To (ft.)
clay	Surface	8
cement	8	90

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on Oct 27 1981

11. MISCELLANEOUS DATA

Yield Test: 3 Hrs. at 7 GPM Well is terminated 12 inches above final grade below

Depth from surface to normal water level 400 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 405 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Will send Mon. Aug 2 Madison laboratory on 19

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Donald C. Kierbaum Registered Well Driller Business Name and Complete Mailing Address Rt 4 Box 75
Dons Well Drilling Boscobel Wis 53805