

FEB 21 1980

State of Wisconsin
Department of Natural Resources
Box 7921
Madison, Wisconsin 53707

NOTE:

White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

WELL CONSTRUCTOR'S REPORT
Form 3300-15 Rev. 12-76

1. COUNTY Crawford CHECK (✓) ONE: Town Village City Name Freeman

2. LOCATION 1/4 Section NW Section 30 Township 10N Range 5W 3. NAME OWNER AGENT AT TIME OF DRILLING CHECK (✓) ONE Susie Slaughter

OR - Grid or Street No. Street Name ADDRESS Box 224

AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, Wisc. 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 50' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected: C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to: Sewer Clearwater Dr. Sewage Sump Clearwater Sump Sewage Sump C.I. Other Clearwater Sump Clearwater Sump Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench

Privy 300' Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home 9. FORMATIONS

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
6	Surface	140	6	120	140	<u>loose sand & gravel</u>	Surface	0	89
						<u>sandstone</u>	89	140	

7. CASING, LINER, CURBING AND SCREEN			
Material, Weight, Specification & Method of Assembly			
Dia. (in.)	From (ft.)	To (ft.)	
<u>6</u>	<u>new black steel</u>	<u>0</u>	<u>108</u>
	<u>R.E. 18.97</u>	<u>Surface</u>	
	<u>A-53</u>		
	<u>Kent Steel</u>		
	Patent		
	<u>hand pump</u>		

8. GROUT OR OTHER SEALING MATERIAL			
Kind	From (ft.)	To (ft.)	
<u>loose sand & gravel</u>	<u>Surface</u>	<u>0</u>	<u>89</u>

10. TYPE OF DRILLING MACHINE USED

Cable Tool Rotary-hammer w/drilling mud & air Jetting with Air Water

Rotary-air w/drilling mud Rotary-hammer & air

Rotary-w/drilling mud Reverse Rotary

Well construction completed on 12-22- 1979

11. MISCELLANEOUS DATA Yield Test: 2 Hrs. at 15 GPM Well is terminated 10 inches above below final grade

Depth from surface to normal water level 80 Ft. Well disinfected upon completion Yes No

Depth of water level when pumping 92 Ft. Stabilized Yes No Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on 1-21- 1980

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R2 Box 4 Boscobel, Wisc. 53805

980