

WELL CONSTRUCTOR'S REPORT

DEPARTMENT OF RESOURCE DEVELOPMENT

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Utica

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)

NW part of Sec. 34 T 10N R 5W

3. OWNER AT TIME OF DRILLING Mr. Vilman Olson

4. OWNER'S COMPLETE MAIL ADDRESS R1 Gays Mills, Wis. 54631

5. Distance in feet from well to nearest:	BUILDING C. I.	SANITARY SEWER TILE	FLOOR DRAIN C. I.	FOUNDATION DRAIN SEWER CONNECTED	FOUNDATION DRAIN INDEPENDENT	WASTE WATER DRAIN C. I.	WASTE WATER DRAIN TILE
(Record answer in appropriate block)	6'	40'	40'			40'	

CLEAR WATER DRAIN C. I.	SEPTIC TANK TILE	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
	125'		135'		62'	150'		

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for: Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	132	6	132	375	Clay & stone	Surface	40
						limestone	40	250

8. CASING, LINER, CURBING, AND SCREEN				10. FORMATIONS		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
6	new plain end black 19,18	Surface	132	sandstone	250	300
				limestone	300	325
				sandstone	325	375

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	40
Cement	40	132

11. MISCELLANEOUS DATA Yield test: 5 Hrs. at 15 GPM Well is terminated 8 inches  above  below final grade

Depth from surface to normal water level 300 ft. Well disinfected upon completion  Yes  No

Depth to water level when pumping 302 ft. Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 11-27-1967

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumphouses, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS R3 Box 84 Bosebel, Wis. 53805

Please do not write in space below

COLIFORM TEST RESULT	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
----------------------	----------------	----------------	-----------	---------