

1. COUNTY Crawford CHECK ONE Town Village City NAME Utica

2. LOCATION (Number and Street or 1/4 section, section, township and range. Also give subdivision name, lot and block numbers when available.)
SW 1/4 of Sec 35 T10N R5W

3. OWNER AT TIME OF DRILLING Mrs. Mary Rita Boland

4. OWNER'S COMPLETE MAIL ADDRESS R7D ~~Seneca~~ Wis., Gay Mills

5. Distance in feet from well to nearest:

(Record answer in appropriate block)	BUILDING	SANITARY	SEWER	FLOOR DRAIN	FOUNDATION DRAIN	WASTE WATER DRAIN
	C. I.	TILE	C. I.	TILE	SEWER CONNECTED	INDEPENDENT
	50'	25'		25'		

CLEAR WATER DRAIN	SEPTIC TANK	PRIVY	SEEPAGE PIT	ABSORPTION FIELD	BARN	SILO	ABANDONED WELL	SINK HOLE
C. I.	TILE							
	150'			165'	50'			

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

6. Well is intended to supply water for:

Farm home

7. DRILLHOLE						10. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
10	Surface	40	6	40	475	Clay & stone	Surface	20
						limestone	20	200
						sandstone	200	310
						limestone	310	420
						sandstone	420	475

8. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
6	plain black new 19.18	Surface	40

9. GROUT OR OTHER SEALING MATERIAL		
Kind	From (ft.)	To (ft.)
Clay	Surface	20
Cement	20	40

11. MISCELLANEOUS DATA		Well construction completed on <u>Sept. 26</u> 19 <u>67</u>	
Yield test: <u>5</u> Hrs. at <u>15</u> GPM		Well is terminated <u>24</u> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade	
Depth from surface to normal water level <u>380</u> ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Depth to water level when pumping <u>385</u> ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Water sample sent to <u>Madison, Wis.</u>		laboratory on: <u>9-28-</u> 19 <u>67</u>	

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE	COMPLETE MAIL ADDRESS
<u>Kenneth Coplan</u> Registered Well Driller	<u>R3 BOX 84 Boxobal, Wis., 53805</u>

Please do not write in space below

COLIFORM TEST RESULT	GAS -- 24 HRS.	GAS -- 48 HRS.	CONFIRMED	REMARKS
<u>983</u>				