

MAR 28 1974

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE Town Village City NAME Freeman

2. LOCATION - 1/4 Section Section Township Range 10 N 6 W 3. OWNER AT TIME OF DRILLING Armini Bergelini
 OR - Grid or street no. Street name ADDRESS Ferryville

AND - If available subdivision name, lot & block no. BD Hudson addition POST OFFICE Wis, 54628
Lot 5 Block 1

4. Distance in feet from well to nearest: BUILDING SANITARY SEWER FLOOR DRAIN FOUNDATION DRAIN WASTE WATER DRAIN
 (Record answer in appropriate block) 5' C. I. TILE C. I. TILE SEWER CONNECTED INDEPENDENT C. I. TILE

CLEAR WATER DRAIN SEPTIC TANK PRIVY SEEPAGE PIT ABSORPTION FIELD BARN SILO ABANDONED WELL SINK HOLE
 C. I. TILE Village sewer

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: home

6. DRILLHOLE						9. FORMATIONS			
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)	
<u>10</u>	<u>Surface</u> ⁰	<u>90</u>	<u>6</u>	<u>90</u>	<u>120</u>	<u>Clay</u>	<u>Surface</u> ⁰	<u>15</u>	
						<u>soft sandstone</u>	<u>15</u>	<u>80</u>	
						<u>nipped with clay</u>			
						<u>hard sandstone</u>	<u>80</u>	<u>120</u>	

7. CASING, LINER, CURBING, AND SCREEN			
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)
<u>6</u>	<u>new black steel plain end 19.18</u>	<u>Surface</u> ⁰	<u>90</u>

8. GROUT OR OTHER SEALING MATERIAL				10. TYPE OF DRILLING MACHINE USED			
Kind	From (ft.)	To (ft.)					
<u>soft sandstone</u> <u>Clay</u>	<u>Surface</u> ⁰	<u>15</u>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary	<input type="checkbox"/> Jetting with	<input type="checkbox"/> Air <input type="checkbox"/> Water
<u>Cement</u>	<u>15</u>	<u>90</u>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air			

11. MISCELLANEOUS DATA
 Yield test: 3 Hrs. at 8 GPM
 Well construction completed on 3-12-1974
 Well is terminated 12 inches above below final grade
 Depth from surface to normal water level 80 ft. Well disinfected upon completion Yes No
 Depth to water level when pumping 92 ft. Well sealed watertight upon completion Yes No

Water sample sent to Madison laboratory on: 3-26-1974

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller COMPLETE MAIL ADDRESS Booscobol
R3 Box 84 Wis, 53805

COLIFORM TEST RESULT	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
<u>985</u>				