

FEB 4 1977

NOTE:
White Copy - Division's Copy
Green Copy - Driller's Copy
Yellow Copy - Owner's Copy

1. COUNTY <u>Crawford</u>		CHECK (✓) ONE: <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City <u>Freeman</u>		Name <u>Freeman</u>	
2. LOCATION 1/4 Section <u>10</u> Section <u>N</u> Township <u>6W</u> Range <u>10</u>		3. NAME <input type="checkbox"/> OWNER <input checked="" type="checkbox"/> AGENT AT TIME OF DRILLING CHECK (✓) ONE <u>Donald Hempy</u>		ADDRESS <u>Box 157</u>	
OR - Grid or Street No. _____ Street Name _____		POST OFFICE <u>Ferrysville, WI</u>		AND - If available subdivision name, lot & block No. <u>A portion of Grant - Lots 3 & 4</u>	
4. Distance in feet from well to nearest: (Record answer in appropriate block) <u>25'</u>		Building Sanitary Bldg. Drain Sanitary Bldg. Sewer Floor Drain Connected To: Storm Bldg. Drain Storm Bldg. Sewer		C.I. Other C.I. Other C.I. Sewer Other Sewer C.I. Other C.I. Other	
Street Sewer San. Storm Other Sewers C.I. Other		Foundation Drain Connected to: Sewage Sump Clearwater Sump		Septic Tank Holding Tank Sewage Absorption Unit	
Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank		Subsurface Pumphouse Nonconforming Existing		Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or	
Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure		Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type)		Other (Give Description) <u>City Sewer - 75'</u>	
5. Well is intended to supply water for: <u>Home</u>		9. FORMATIONS			
6. DRILLHOLE		Kind		From (ft.) To (ft.)	
Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)		<u>Clay</u>		<u>0</u> <u>10</u>	
<u>10</u> <u>0</u> <u>Surface</u> <u>52</u> <u>6</u> <u>52</u> <u>100</u>		<u>Shalestone</u>		<u>10</u> <u>60</u>	
		<u>Hard sandstone</u>		<u>60</u> <u>80</u>	
7. CASING, LINER, CURBING AND SCREEN					
Material, Weight, Specification & Method of Assembly		From (ft.) To (ft.)			
Dia. (in.) <u>6</u> <u>P.E. New Black Steel</u> <u>18.97</u>		<u>0</u> <u>Surface</u> <u>52</u>			
<u>Valley Steel</u> <u>A-53</u>					
<u>Pitless Adaptor</u>					
8. GROUT OR OTHER SEALING MATERIAL		10. TYPE OF DRILLING MACHINE USED			
Kind From (ft.) To (ft.)		<input type="checkbox"/> Cable Tool <input type="checkbox"/> Rotary-hammer w/drilling mud & air <input type="checkbox"/> Jetting with <input type="checkbox"/> Air <input type="checkbox"/> Water			
<u>Clay</u> <u>0</u> <u>Surface</u> <u>7</u>		<input type="checkbox"/> Rotary-air w/drilling mud <input checked="" type="checkbox"/> Rotary-hammer & air <input type="checkbox"/> Reverse Rotary			
<u>Cement</u> <u>7</u> <u>52</u>		Well construction completed on <u>Jan. 13</u> 19 <u>77</u>			
11. MISCELLANEOUS DATA		Well is terminated <u>10</u> inches <input checked="" type="checkbox"/> above final grade <input type="checkbox"/> below			
Yield Test: <u>4</u> Hrs. at <u>5</u> GPM		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth from surface to normal water level <u>55</u> Ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No			
Depth of water level when pumping <u>60</u> Ft. Stabilized <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No					
Water sample sent to <u>Madison</u> laboratory on <u>Jan. 31</u> 19 <u>77</u>					

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Coplan Registered Well Driller Complete Mail Address R3, Box 84 - Boscobel, WI