

**WELL CONSTRUCTOR'S REPORT TO WISCONSIN STATE BOARD OF HEALTH**  
See Instructions on Reverse Side

SEP 26 1946

1. County Crawford } Town Ferryville Wis. ✓  
 Village Ferryville  
 City Ferryville

2. Location Village Of Ferryville T10N R6W

3. Owner or Agent Pearl Hutson

4. Address Ferryville, Wisconsin

5. From well to nearest: Building 5 ft; sewer        ft; drain        ft; septic tank        ft;  
 dry well or filter bed        ft; abandoned well        ft.

6. Well is intended to supply water for: Residence

**7. DRILLHOLE OR EXCAVATION:**

Dia. (in.)	From (ft.)	To (ft.)
<u>8</u>	<u>0</u>	<u>50</u>
<u>6</u>	<u>50</u>	<u>82</u>

**8. CASING AND LINER PIPE OR CURBING:**

Dia. (in.)	Kind	From (ft.)	To (ft.)
<u>6</u>	<u>Standard Weight</u>		
	<u>Wrought Iron Pipe</u>	<u>0</u>	<u>52</u>

**9. GROUT:**

Kind	From (ft.)	To (ft.)
<u>Puddled Clay</u>	<u>0</u>	<u>50</u>

**10. FORMATIONS:**

Kind	Thick-ness (ft.)	Total Depth (ft.)
<u>Sandy Soil</u>	<u>50</u>	<u>50</u>
<u>White Sand Rock</u>	<u>32</u>	<u>82</u>
<u>(Water Bearing)</u>		

**11. MISCELLANEOUS DATA:**

Yield test:        Hrs. at        GPM.  
 Depth from surface to water: 42 ft.  
 Water-level when pumping: 40 ft.  
 Water sample sent to laboratory at La Cress,  
Wisconsin. on July 25 1946

Construction of the well was completed on         
July 24 1946

The well is terminated In 60 inches  
 (above) (below) the permanent grade.

Was the well disinfected upon completion?  
 Yes  No       

Was the well sealed watertight upon completion?  
 Yes  No       

Signature *Jim Parkhurst*  
 Registered Well Driller  
Jim Parkhurst

Route 1, Box 157  
 Complete Mail Address  
Elroy, Wisconsin.