

NOTE:

White Copy - Division's Copy  
 Green Copy - Driller's Copy  
 Yellow Copy - Owner's Copy

1. COUNTY Crawford CHECK (✓) ONE:  Town  Village  City Name Freeman

2. LOCATION 1/4 Section SW Section 2 Township 10N Range 6W 3. NAME  OWNER  AGENT AT TIME OF DRILLING CHECK (✓) ONE Donald Stover

OR - Grid or Street No. Street Name ADDRESS RFD

AND - If available subdivision name, lot & block No. POST OFFICE Ferrysville, Wis, 54628

4. Distance in feet from well to nearest: (Record answer in appropriate block) Building 25' Sanitary Bldg. Drain C.I. Other Sanitary Bldg. Sewer C.I. Other Floor Drain Connected C.I. Sewer Other Sewer Storm Bldg. Drain C.I. Other Storm Bldg. Sewer C.I. Other Sewage Absorption Unit 75'

Street Sewer San. Storm Other Sewers C.I. Other Foundation Drain Connected to Sewer Clearwater Dr. Sewage Sump C.I. Other Clearwater Sump Septic Tank Holding Tank Sewage Absorption Unit Seepage Pit Seepage Bed Seepage Trench 60'

Privy Pet Waste Pit Pit: Nonconforming Existing Well Pump Tank Subsurface Pumproom Nonconforming Existing Barn Gutter Animal Barn Pen Animal Yard Silo With Pit Glass Lined Storage Facility Silo w/o Pit Earthen Silage Storage Trench Or Pit

Temporary Manure Stack Watertight Liquid Manure Tank Solid Manure Storage Structure Subsurface Gasoline or Oil Tank Waste Pond or Land Disposal Unit (Specify Type) Other (Give Description)

5. Well is intended to supply water for: Country home

6. DRILLHOLE Dia. (in.) From (ft.) To (ft.) Dia. (in.) From (ft.) To (ft.)

10	Surface	96	6	96	140
----	---------	----	---	----	-----

7. CASING, LINER, CURBING AND SCREEN Material, Weight, Specification & Method of Assembly Dia. (in.) From (ft.) To (ft.)

6	new black steel P.E. 18.97 A-53	0	96
	Valley steel		
	Pitless adaptor		

8. GROUT OR OTHER SEALING MATERIAL Kind From (ft.) To (ft.)

Clay	Surface	7
Cement	7	96

9. FORMATIONS Kind From (ft.) To (ft.)

Clay & stone	Surface	63
soft shale stone	63	80
hard shale stone	80	140

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Rotary-air w/drilling mud  Rotary-w/drilling mud  Rotary-hammer w/drilling mud & air  Rotary-hammer & air  Reverse Rotary  Jetting with  Air  Water

Well construction completed on 9-9-1978

11. MISCELLANEOUS DATA Yield Test: 3 Hrs. at 5 GPM Well is terminated 10 inches  above final grade  below

Depth from surface to normal water level 80 Ft. Well disinfected upon completion  Yes  No

Depth of water level when pumping 92 Ft. Stabilized  Yes  No Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on 9-26-1978

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, method of finishing the well, amount of cement used in grouting, blasting, etc., should be given on reverse side.

Signature Kenneth Cyprian Registered Well Driller Complete Mail Address Roseobel, Wis. R3 Box 84 53805