

WELL CONSTRUCTOR'S REPORT  
FORM 3300-15

NOV 5 1971  
STATE OF WISCONSIN  
DEPARTMENT OF NATURAL RESOURCES  
Box 450  
Madison, Wisconsin 53701

**NOTE**  
WHITE COPY - DIVISION'S COPY  
GREEN COPY - DRILLER'S COPY  
YELLOW COPY - OWNER'S COPY

1. COUNTY Crawford CHECK ONE  Town  Village  City NAME Freemont

2. LOCATION - 1/4 Section NE Section 2 Township 10N Range 6W

OR - Grid or street no. Street name

3. OWNER AT TIME OF DRILLING Arnold Emerson  
ADDRESS R1

AND - If available subdivision name, lot & block no. POST OFFICE Ferrisville, Wis. 54628

4. Distance in feet from well to nearest:

|           |                |             |                  |                   |
|-----------|----------------|-------------|------------------|-------------------|
| BUILDING  | SANITARY SEWER | FLOOR DRAIN | FOUNDATION DRAIN | WASTE WATER DRAIN |
| C. I.     | C. I.          | C. I.       | SEWER CONNECTED  | INDEPENDENT       |
| <u>6'</u> | <u>20'</u>     | <u>20'</u>  |                  |                   |

(Record answer in appropriate block)

|                   |             |       |             |                  |             |      |                |           |
|-------------------|-------------|-------|-------------|------------------|-------------|------|----------------|-----------|
| CLEAR WATER DRAIN | SEPTIC TANK | PRIVY | SEEPAGE PIT | ABSORPTION FIELD | BARN        | SILO | ABANDONED WELL | SINK HOLE |
| C. I.             | TILE        |       |             |                  |             |      |                |           |
|                   | <u>65'</u>  |       |             | <u>80'</u>       | <u>200'</u> |      |                |           |

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: Country home

| 6. DRILLHOLE |                |           |            |            |            | 9. FORMATIONS                 |                |            |
|--------------|----------------|-----------|------------|------------|------------|-------------------------------|----------------|------------|
| Dia. (in.)   | From (ft.)     | To (ft.)  | Dia. (in.) | From (ft.) | To (ft.)   | Kind                          | From (ft.)     | To (ft.)   |
| <u>10</u>    | <u>Surface</u> | <u>49</u> | <u>6</u>   | <u>49</u>  | <u>100</u> | <u>Clay</u>                   | <u>Surface</u> | <u>20</u>  |
|              |                |           |            |            |            | <u>loose stone &amp; clay</u> | <u>20</u>      | <u>40</u>  |
|              |                |           |            |            |            | <u>hard shale stone</u>       | <u>40</u>      | <u>80</u>  |
|              |                |           |            |            |            | <u>sandstone</u>              | <u>80</u>      | <u>100</u> |

7. CASING, LINER, CURBING, AND SCREEN

| Dia. (in.) | Kind and Weight                        | From (ft.)     | To (ft.)  |
|------------|--|----------------|-----------|
| <u>6</u>   | <u>new black steel plain end 19.18</u> | <u>Surface</u> | <u>49</u> |

8. GROUT OR OTHER SEALING MATERIAL

| Kind          | From (ft.)     | To (ft.)  |
|---------------|----------------|-----------|
| <u>Clay</u>   | <u>Surface</u> | <u>20</u> |
| <u>Cement</u> | <u>20</u>      | <u>49</u> |

10. TYPE OF DRILLING MACHINE USED

Cable Tool  Direct Rotary  Reverse Rotary

Rotary - air w/drilling mud  Rotary - hammer with drilling mud & air  Jetting with Air  Water

Well construction completed on 10-19- 19 71

Well is terminated 10 inches  above  below final grade

Well disinfected upon completion  Yes  No

Well sealed watertight upon completion  Yes  No

Water sample sent to Madison laboratory on: 11-2- 19 71

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE Kenneth Coplan Registered Well Driller

COMPLETE MAIL ADDRESS Boacobel, R3 Box 84 Wis., 53805

Please do not write in space below

|                                    |               |               |           |         |
|------------------------------------|---------------|---------------|-----------|---------|
| COLIFORM TEST RESULT<br><u>996</u> | GAS - 24 HRS. | GAS - 48 HRS. | CONFIRMED | REMARKS |
|------------------------------------|---------------|---------------|-----------|---------|

REV. 3-71