

AUG 31 1972

12073

WELL CONSTRUCTOR'S REPORT
FORM 3300-15

STATE OF WISCONSIN
DEPARTMENT OF NATURAL RESOURCES
Box 450
Madison, Wisconsin 53701

NOTE

WHITE COPY - DIVISION'S COPY
GREEN COPY - DRILLER'S COPY
YELLOW COPY - OWNER'S COPY

1. COUNTY <i>Crawford</i>	CHECK ONE <input checked="" type="checkbox"/> Town <input type="checkbox"/> Village <input type="checkbox"/> City	NAME <i>Freeman</i>
------------------------------	--	------------------------

2. LOCATION - 1/4 Section <i>NE</i>	Section <i>4</i>	Township <i>10 N</i>	Range <i>6 W</i>	3. OWNER AT TIME OF DRILLING <i>Alice Ugum</i>
OR - Grid or street no.	Street name			ADDRESS <i>R7D</i>

AND - If available subdivision name, lot & block no.

POST OFFICE
Ferrisville

4. Distance in feet from well to nearest: (Record answer in appropriate block)	BUILDING <i>25'</i>	SANITARY SEWER C.I. <i>40'</i>	TILE	FLOOR DRAIN C.I.	TILE	FOUNDATION DRAIN SEWER CONNECTED	INDEPENDENT	WASTE WATER DRAIN C.I.	TILE
---	------------------------	-----------------------------------	------	---------------------	------	-------------------------------------	-------------	---------------------------	------

CLEAR WATER DRAIN C.I.	SEPTIC TANK TILE <i>85'</i>	PRIVY	SEEPAGE PIT <i>90'</i>	ABSORPTION FIELD	BARN <i>100'</i>	SILO <i>120'</i>	ABANDONED WELL	SINK HOLE
---------------------------	--------------------------------	-------	---------------------------	------------------	---------------------	---------------------	----------------	-----------

OTHER POLLUTION SOURCES (Give description such as dump, quarry, drainage well, stream, pond, lake, etc.)

5. Well is intended to supply water for: *Farm home*

6. DRILLHOLE						9. FORMATIONS		
Dia. (in.)	From (ft.)	To (ft.)	Dia. (in.)	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<i>10</i>	<i>Surface</i>	<i>271</i>	<i>6</i>	<i>271</i>	<i>580</i>	<i>Clay</i>	<i>Surface</i>	<i>55</i>
						<i>sandstone</i>	<i>55</i>	<i>215</i>

7. CASING, LINER, CURBING, AND SCREEN				9. FORMATIONS		
Dia. (in.)	Kind and Weight	From (ft.)	To (ft.)	Kind	From (ft.)	To (ft.)
<i>6</i>	<i>new black steel plain end 19.18</i>	<i>Surface</i>	<i>271</i>	<i>limestone</i>	<i>215</i>	<i>250</i>
				<i>hard shalestone</i>	<i>250</i>	<i>310</i>
				<i>Sandstone</i>	<i>310</i>	<i>480</i>
				<i>limestone</i>	<i>480</i>	<i>540</i>
				<i>Sandstone</i>	<i>540</i>	<i>580</i>

8. GROUT OR OTHER SEALING MATERIAL			10. TYPE OF DRILLING MACHINE USED		
Kind <i>Clay</i>	From (ft.) <i>Surface</i>	To (ft.) <i>55</i>	<input type="checkbox"/> Cable Tool	<input type="checkbox"/> Direct Rotary	<input type="checkbox"/> Reverse Rotary
<i>Cement</i>	<i>55</i>	<i>271</i>	<input type="checkbox"/> Rotary - air w/drilling mud	<input checked="" type="checkbox"/> Rotary - hammer with drilling mud & air	<input type="checkbox"/> Jetting with Air <input type="checkbox"/> Water
			Well construction completed on <i>8-18-1972</i>		

11. MISCELLANEOUS DATA			Well is terminated <i>10</i> inches <input checked="" type="checkbox"/> above <input type="checkbox"/> below final grade
Yield test: <i>3</i> Hrs. at <i>10</i> GPM	Depth from surface to normal water level <i>480</i> ft.		Well disinfected upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
	Depth to water level when pumping <i>495</i> ft.		Well sealed watertight upon completion <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No

Water sample sent to *Madison* laboratory on: *8-28-1972*

Your opinion concerning other pollution hazards, information concerning difficulties encountered, and data relating to nearby wells, screens, seals, type of casing joints, method of finishing the well, amount of cement used in grouting, blasting, sub-surface pumprooms, access pits, etc., should be given on reverse side.

SIGNATURE <i>Kenneth Copian</i> Registered Well Driller	COMPLETE MAIL ADDRESS <i>Boscobel Wis., 53805</i>
---	--

Please do not write in space below

COLIFORM TEST RESULT <i>997</i>	GAS - 24 HRS.	GAS - 48 HRS.	CONFIRMED	REMARKS
------------------------------------	---------------	---------------	-----------	---------